

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

Zhejiang Austa Green Energy Technology Co., Ltd.
Floor 1, Building 7, No.136, Haichuan Road, Jiangbei Area
Ningbo City, Zhejiang Province
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules



Valid from: 2023-03-21

Valid until: 2028-03-20

Certification program:	P12-VA-01 Rev. 17 09.20
Certification fundamental(s):	IEC / EN 61215-1:2016; IEC / EN 61215-1-1:2016; IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018; IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018; IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.
Registered No.:	44 780 23 406749 - 065
Manufacturer:	see Annex 1
Test Report No.:	492012340.001
File No.:	PVP11016/22P-05


TÜV NORD CERT GmbH
Certification Body
Consumer Products



Essen, 2023-03-21

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 23 406749 - 065

Seite / Page 1 von / of 1

Aktenzeichen: / File reference: PVP11016/22P-05

2023-03-21

Manufacturer:

Manufacturer: **Ningbo Osda Solar Co., Ltd.**
1-1, No.136, Haichuan Road, Jiangbei Area
Ningbo City, Zhejiang Province, P.R.China

Factory inspection report no.: 862010428.004

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	PV Modules with Half-cut 210mm TOPCon Mono-crystalline Silicon Solar Cells: 132 cells: AUxxx-33V-MH (xxx=670-700, in increment of 5) 120 cells: AUxxx-30V-MH (xxx=610-635, in increment of 5) 110 cells: AUxxx-28V-MH (xxx=560-580, in increment of 5) 100 cells: AUxxx-25V-MH (xxx=510-530, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	30A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)
Module types:	PV Modules with Half-cut 182mm TOPCon Mono-crystalline Silicon Solar Cells: 156 cells: AUxxx-39V-MH (xxx=590-620, in increment of 5) 144 cells: AUxxx-36V-MH (xxx=550-570, in increment of 5) 132 cells: AUxxx-33V-MH (xxx=500-525, in increment of 5) 120 cells: AUxxx-30V-MH (xxx=460-475, in increment of 5) 108 cells: AUxxx-27V-MH (xxx=410-430, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products